ROYAL BERKSHIRE

My reference: PG/CB

Your reference: 08/00954/COMIND

When dialling ask for: Peter Gray Direct telephone line: 0118 932 2732

Email address:

waterofficer@rbfrs.co.uk

Head Of Planning & Transport Strategy

West Berkshire Council

West Berkshire District Council

Market Street

Newbury RG14 5LD



Royal Berkshire Fire and Rescue Service

103 Dee Road Tilehurst Reading Berkshire **RG30 4FS**

Telephone 0118 945 2888 Fax 0118 959 0510 Web www.rbfrs.co.uk

Chief Fire Officer Iain Cox MA BSc(Hons) MCIPD

Monday, 02 June 2008

Dear Mr Lugg

AtomicWeapons Est. Burghfield, Reading

With reference to your letter dated 27 May 2008. I would make the following comments:

There are at present, no available public mains in this area to provide a suitable water supply in order to effectively fight a fire. This Authority would therefore request that part of any planning consent terms include the requirement for the applicant to provide suitable private fire hydrant(s), or other suitable emergency water supplies to meet Royal Berkshire Fire & Rescue Service requirements.

Access requirements for Fire Fighting are to meet the functional requirements the Building Regulations 1991 and the relevant provisions of the Berkshire Act. It should be noted that any gates required for emergency access should provide a minimum 3.1m clear opening.

The layout plans provided have not been reviewed for fire safety provisions. This is the responsibility of your Buildings Regulations Department or Approved Inspector, in consultation with this Authority as part of a Building Regulations submission.

If I can be of further assistance, please do not hesitate to contact me.

Yours sincerely

Peter Gray **Water Officer**