


# ROYAL BERKSHIRE FIRE AND RESCUE SERVICE



My reference: PG/CB  
Your reference: 09/02396/COMIND

When dialling ask for: Peter Gray  
Direct telephone line: 0118 932 2732  
Email address: [waterofficer@rbfrs.co.uk](mailto:waterofficer@rbfrs.co.uk)

Head Of Planning & Transport Strategy  
West Berkshire Council  
West Berkshire District Council  
Market Street  
Newbury  
RG14 5LD



**Royal Berkshire  
Fire and Rescue Service**  
103 Dee Road  
Tilehurst  
Reading  
Berkshire  
RG30 4FS

Telephone 0118 945 2888  
Fax 0118 959 0510  
Web [www.rbfrs.co.uk](http://www.rbfrs.co.uk)

*Chief Fire Officer*  
Iain COX OFSM MA BSc(Hons) MCIPD

15 December 2009

Dear Mr Lugg

## **AWE Aldermaston, Aldermaston, Reading**

With reference to your correspondence dated 01 December 2009, I would make the following comments:

There are at present, no available public mains in this area to provide a suitable water supply in order to effectively fight a fire. This Authority would therefore request that part of any planning consent terms include the requirement for the applicant to provide suitable private fire hydrant(s), or other suitable emergency water supplies to meet Royal Berkshire Fire & Rescue Service requirements.

Access requirements for Fire Fighting are to meet the functional requirements the Building Regulations 1991 and the relevant provisions of the Berkshire Act. It should be noted that any gates required for emergency access should provide a minimum 3.1m clear opening.

The layout plans provided have not been reviewed for fire safety provisions. This is the responsibility of your Buildings Regulations Department or Approved Inspector, in consultation with this Authority as part of a Building Regulations submission.

If I can be of further assistance, please do not hesitate to contact me.

Yours sincerely

Peter Gray  
Water Officer